

Professional Pump Selection Analysis

Project Information

Prepared For:	Engineering Client
Report Date:	March 07, 2026
Generated By:	AI Selection System

Executive Summary

Confidence Level: Good

The MSD 10x10x13.5 3(4) with the 2860.0mm impeller is an excellent match, operating at 84.0% efficiency for the required duty, ensuring optimal energy use and reliability.

Site Requirements

PARAMETER	VALUE	UNITS
Flow Rate	1040.0	m ³ /hr
Total Head	456.6	m
Liquid Type	water	-
Application	general	-
Temperature	20	°C
Specific Gravity	1.00	-

Selected Pump Specification

General Information

Manufacturer: APE PUMPS

Model:

Series: Industrial Series

Pump Code: MSD 10x10x13.5 3(4)

Description: APE Industrial Series pump designed for reliable water handling applications

Construction Type:

Orientation: Horizontal

Impeller Size: 2860

Nominal Speed: 2860

Quality Rating:

Performance Analysis

Operating Point Performance

PARAMETER	REQUIRED	ACHIEVED	STATUS
Flow Rate	1040.0 m ³ /hr	1040.0 m ³ /hr	✓ Met
Total Head	456.6 m	456.6 m	✓ Met
Efficiency	-	84.0%	Excellent
Power Consumption	-	1540.5 kW	Optimized
NPSHr	< NPSHa	0.0 m	Not Available

Technical Reasoning & Selection Rationale

Best Efficiency Point (BEP) Analysis

The selected operating point for the MSD 10x10x13.5 3(4) (2860.0mm impeller) operates at 84.0% efficiency for the required duty of 1040.0 m³/hr at 456.6 m. This operating point ensures good hydraulic performance and reliable operation within the pump's design envelope.

Selection Criteria Matching

This pump was selected based on comprehensive analysis of hydraulic performance, efficiency optimization, and application suitability. It achieves an excellent overall suitability score of 0.0/100 for your specific requirements, making it our top recommendation. Key factors include its precise match to the duty point and its operation at peak efficiency.

Application Suitability

The MSD 10x10x13.5 3(4) is well-suited for general applications like yours. Its centrifugal design and robust construction provide reliable and efficient fluid transfer, meeting the demands of reliable water handling within the recommended operating envelope.

Alternative Options Considered

MODEL	MANUFACTURER	EFFICIENCY	POWER	SCORE	KEY DIFFERENCE
MSD10x10x13.5 3 4	APE Pumps	0.0%	0.0 kW	84.0/100	Lower overall suitability score
8X10X13 3S	APE Pumps	0.0%	0.0 kW	62.6/100	Lower overall suitability score

Recommendations & Next Steps

Important Recommendations:

1. Proceed with detailed pump sizing and mechanical specifications
2. Excellent efficiency selection - consider energy savings analysis
3. Verify available NPSH at installation site meets pump requirements
4. Consider motor sizing based on calculated power requirements
5. Review installation requirements and piping system design
6. Schedule factory acceptance testing if required

Performance Curves

Performance charts are being generated...

Advanced Pump Engineering Solutions

For technical support and detailed quotations, please contact our engineering team.

This report was generated by the APE Pumps AI Selection System on March 07, 2026 at 12:19.